

between the sidewalk and street or gutter shall be provided.

Longitudinal Slope

The longitudinal slope of a sidewalk shall not exceed the grade of the adjacent road or 5%, whichever is greater.

Cross Slope

Cross slope of a sidewalk shall not be less than 1% or greater than 2%.

Level Areas

If a sidewalk has a longitudinal slope exceeding 5% for at least 400 feet, a 60-inch long landing with a maximum slope of 2% shall be provided every 400 feet of sidewalk length.

Changes in Level

Changes in level up to 1/4 inch may be vertical and without edge treatment. Changes in level between 1/4 and 1/2 inch shall be beveled with a slope no greater than 1 horizontal to 2 vertical. Changes greater than 1/2 inch shall be a ramp sloping no more than 8.3%. Multiple changes in level shall be separated horizontally by at least 30 inches.

Drive Approaches

Where a sidewalk crosses a drive approach, the minimum width of 48 inches and the maximum cross slope of 2% shall be provided for the entire width of the drive approach. Drive approach entries shall not be designed or used as curb ramps.

Curb ramps were evaluated for compliance using the following definitions and requirements from the ADAAG and CBC Title 24 standards:

Curb Ramp

A curb ramp is sloping pedestrian way which provides access between a sidewalk and a surface located above or below an adjacent curb face. Each curb ramp shall have parallel relief lines embedded in cement surrounding ramp on level areas of landings; they shall have a grooved border 12-inches wide at each level surface of the sidewalk along the top and each side approximately 3/4-inch on center; curb ramps constructed between the face of curb and street shall have a grooved border at the level surface of the sidewalk; and curb ramps shall be a minimum of 4 feet in width and shall lie, generally, in a single sloped plane, with a minimum of surface warping and cross slope.

Cross Slope

Cross slope is perpendicular to direction of travel or slope in center area of ramp. Cross slope must not exceed a 2% grade.

Flares

Flares are the grade from the base of the curb ramp toward its side landings. Flares must not exceed a 10% grade.

Level Landings

Level landings are the areas surrounding the entire rear and sides of a ramp. A level

landing must not exceed a 2% grade.

Slope

Slope is the vertical grade from the curb ramp base toward its top, parallel to direction of travel, and perpendicular to cross slope. Slope must not exceed 8.33% grade.

Smooth Transitions

A smooth transition is that point where the curb ramp meets the adjoining gutter or road surface. It must be smooth and at the same level. Counter slopes of adjoining gutters and road surfaces immediately adjacent to the curb ramp shall not be steeper than 1:20. The adjacent surfaces at transitions at curb ramps to walks, gutters, and streets shall be at the same level.

Truncated Domes

Truncated domes are the plastic relief dots or miniature bumps applied to the center base of a curb ramp as a detectable warning device.

2.5.3 Field Data Summary

The collected information for each inspected sidewalk and curb ramp facility is shown on the field survey forms included in Appendix A. The field data sheets include a checklist of all ADA components for each pedestrian facility including those that are compliant and those that did not meet the standards. The survey identifies ADA barriers that will be considered for future capital improvement projects.

3.0 ADA Compliance and Programs

3.1 Introduction

The City of Firebaugh has taken steps in identifying ADA barriers within the City's building and public right of way and eliminating such barriers as feasible. Information on funding opportunities for removing existing ADA barriers, a list of recent projects, on-going practices for ADA improvements, a resources guide for facilitating accessibility, and the process for citizen accommodations has been included in the report.

3.2 Public Outreach

An ADA notice will be available from the City of Firebaugh informing residents of the ongoing ADA self-evaluation for valuable input from City residents. A copy of the public notice and posting is included in Appendix C.

A survey for organizations and individuals with disabilities will be used to collect their opinions and recommendations on existing ADA conditions. A copy of the survey form is included in Appendix D.

3.3 Citizen Request Process

The Citizen Request Process for the City of Firebaugh shall consist of:

- Requests for reasonable modification in programs or services shall be made to the ADA Coordinator.
- The ADA Coordinator shall meet with the individual with a disability to identify which programs or facilities limit participation and what modifications can be made.
- City staff from relevant programs or services shall determine the reasonable modification. Staff will consult with the City's ADA Coordinator as appropriate.
- The ADA Coordinator shall document the modification(s) that was offered and the response of the person with the disability to the modification(s) offered. All accessibility requests shall be tracked. The ADA requests will be analyzed periodically to look for global issues that can be addressed and problems than can be solved proactively.

If individuals with a disability are not satisfied with the results of this process, they should be directed to the City's ADA Compliant Procedure.

3.4 Nondiscrimination Policy

The City of Firebaugh has acknowledge Title II of the ADA and its nondiscrimination policies. The City has posted a notice stating that they will not discriminate against individuals with disabilities on the basis of disability in its services, programs, or activities. The City will not discriminate on the basis of disability in its employment practices. The City will provide appropriate communication services for individuals so they can equally participate in City

programs, services, and activities. The City will make reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services and activities. A copy of the Notice under the American with Disabilities Act is included in Appendix E.

3.5 Annual Capital Improvements Program

The City's Capital Improvement Program (CIP) for street projects will be coordinated with the future removal of ADA barriers where non-compliant curb ramps and sidewalks are identified as part of the project. These non-compliant facilities will be scheduled for upgrade to applicable standards in tandem with the corresponding Capital Improvement Project. Recently completed projects that included repairs to sidewalks and construction of ADA compliant curb ramps are as follows:

2014- Safe Routes to School Federal Cycle 3 SRTS-5224(016)- This project constructed new sidewalk providing continuity between existing pedestrian paths and 25 ADA curb ramps.

2013- Safe Routes to School State Cycle 10 SR2SL-5224(018)- This project constructed 13 ADA curb ramps and replaced several driveways to provide continuity in ADA pathways at various locations in the City.

2010- Safe Routes to School SRTSL-5224(012)- This project constructed 19 ADA curb ramps and over 15,000 square feet of sidewalk in various locations in the City.

2010- Reconstruction of Downtown Sidewalk Ramps ESPL-5224(014)- This projected constructed sidewalk and ADA curb ramps improvements at 4 corners within the City's downtown area.

3.6 Funding Sources

There are various sources of current and potential funding for capital improvement projects that can incorporate barrier removal components. These funding sources include:

Gas Tax and Transportation Development Act (TDA) and Measure C

The road/transportation improvements funding sources generally known as the "TDA" and Measure C have a small component set aside for ADA compliance improvements.

Road Maintenance and Rehabilitation

The City can incorporate any non-compliant curb ramps and sidewalks into the scope of work for all street improvement projects programmed for the rehabilitation or reconstruction of an existing road. State and Federal funding sources such as CMAQ, RSTP, HSIP, and ATP would fund eligible sidewalks and curb ramp improvements.

Caltrans Projects

Caltrans periodically performs work along the State highways within the City limits. Their projects typically include curb ramps, sidewalks and other ADA accessibility related

improvements. The City will coordinate with Caltrans to ensure that all ADA barriers within the scope of their projects are completed as part of the work.

Development Projects

City staff will coordinate with private developers for all improvements within the City's rights of way. Conditions of approval for new development will require improvements for ADA compliant sidewalks and curb ramps directly adjacent and within the area of influence of the development property.

Special Funding Programs

The Community Development Block Grant (CDBG) Program provides an opportunity to seek grant funding for public improvements that include ADA components. Other funding sources that could be used for the ADA improvements include sales tax funds, developer fees, assessment districts and other eligible City funds.

3.7 Municipal Facilities

3.7.1 Priority Plan for Facility Barrier Removal

Since not all of the barriers can be removed in order to provide program access, those barriers that limit access to public programs, services, and activities are given first priority. The City of Firebaugh has prioritized the removal of ADA barriers in City facilities using the following guidelines:

Priority One: The highest priority is placed on those barrier removal items that provide accessibility at the main entrance of a facility or improve a path of travel to the portion of the facility where program activities take place.

Examples:

- Connection to the public right-of-way
- Parking and passenger loading
- Entrance walks
- Entrance ramps
- Entrance stairs
- Entrance doors

Priority Two: A second level priority is placed on those barrier removal items that improve or enhance access to program use areas.

Examples:

- Transaction counters
- Conference and meeting rooms

- Public offices
- Recreation environments/features
- Public restrooms

Priority Three: A third level priority is placed on those barrier removal items that improve access to amenities serving program areas.

Examples:

- Drinking fountains
- Public telephones
- Vending machines

Priority Four: A fourth level of priority is assigned to areas or features that are not required to be modified because there are no public programs located in the facility or portion of the facility, or because there are other locations that provide access to the program.

The City has completed the self-evaluation and recognizes existing ADA barriers within its municipal facilities. The results of this survey will assist the City in removing and eliminating the barriers with future improvement projects. Facilities requiring reconstruction will be addressed in order of priority and will be considered based on the greatest impact to the public.

3.8 Public Rights of Way

3.8.1 Priority Plan for PROW Barrier Removal

Since the City of Firebaugh is not required to provide program accessibility in every direction within the public rights of way, the City has determined that alternative routes that make use of existing curb cuts and require individuals with disabilities to travel only a marginally longer route is an acceptable means to satisfy ADA accessibility requirements. The City has prioritized the removal of ADA barriers in public rights of way using the following ranking criteria:

- Priority 1 - Repair of hazardous conditions
- Priority 2 - Construction of new curb ramps to connect existing sidewalks
- Priority 3 - Repair of existing curb ramps or sidewalks that do not comply with ADAAG technical requirements and State of California standards
- Priority 4 - Construction of sidewalks at facility gaps

The City of Firebaugh has also established an ongoing procedure for constructing curb ramps and sidewalks upon request in areas frequented by individuals with disabilities who are residents, employees, or visitors. The City's sidewalk and curb ramp program will be guided using the following ranking criteria:

- *Provide access to state or local governmental facilities or offices*

- *Provide access to places of public accommodation for commercial, medical, professional, educational, or recreational services*
- *Provide access to public transit*
- *Enhance safety at pedestrian crossings*
- *Create connected systems of accessible pathways*

In addition, when streets, roads, or highways are newly built or altered, the City will provide ramps or sloped areas wherever there are curbs or other barriers to entry from a sidewalk or path. Likewise, when new sidewalks or paths are built or altered, they must contain curb ramps or sloped areas wherever they intersect with streets, roads, or highways.

The City has completed the self-evaluation and recognizes existing ADA barriers within its public rights of way. The results of this survey will assist the City in removing and eliminating the barriers with future improvement projects with the focus on sidewalks and curb ramps. Facilities requiring reconstruction will be addressed in order of priority and will be considered based on the greatest impact to the public.

4.0 ADA Complaint Procedures

4.1 Policy for ADA Complaints

Public entities receiving federal funding area required to designate at least one responsible employee to coordinate Americans with Disabilities Act (ADA) compliance. The City of Firebaugh has designated the Public Works Director as its primary ADA Coordinator. The ADA Coordinator is responsible for coordinating the efforts of the City to comply with Title II and for investigating any complaints that the City has violated Title II of the ADA. The ADA Coordinator is also responsible for coordinating the efforts of the City to comply with Title 24 and all other applicable State and Federal physical and program accessibility requirements.

All complaints or grievances submitted to the City of Firebaugh must be in writing on the designated form and contain specific information about the alleged violation or discrimination including: name; address; telephone number of the complainant; and the location, date, and a complete description of the problem. Anonymous complaints or grievances will not be accepted. Complaints or grievances will be kept confidential to the greatest extent possible, unless ordered released by a court of competent jurisdiction (see Evidence Code 1040). Alternative means of filing complaints or grievances may be accepted at the discretion of the ADA Coordinator. These may be submitted by telephone, e-mail (confidentiality cannot be assured), letter, personal interview, or tape recording, upon request. However, all complaints or grievances must provide all the information required consistent with the format of the official complaint form included in Appendix F.

All complaints must be submitted by the complainant or his/her designee to the ADA Coordinator at the below location or, upon approval of a request to submit in an alternative method, by telephone at (559)659-2043 (Voice) or via e-mail at publicworks@ci.firebaugh.ca.us. Complaints should be submitted as soon as possible, but no later than 60 calendar days, after the date of the alleged violation or discriminatory act.

Ben Gallegos, ADA Coordinator
1133 "P" Street
Firebaugh, CA 93622
(559) 659-2043

If a complaint is regarding building or facility inaccessibility, the ADA Coordinator will forward the complaint within 5 business days to the City of Firebaugh's Building Section for investigation and will formally acknowledge receipt of the complaint to the complainant.

For all other complaints or grievances, the ADA Coordinator will contact the complainant to discuss the complaint or grievance within 10 business days after receipt of the complaint or grievance. Within 30 calendar days of this contact, the ADA Coordinator will respond in writing and, where appropriate, in an alternative format accessible to the complainant. The response will explain the position of the City of Firebaugh and offer options for substantive and reasonable resolution of the complaint or grievance.

If the response by the ADA Coordinator does not satisfactorily resolve the issue, the decision

may be appealed to the City Manager or his/her designee within 30 calendar days following receipt of the response.

Within 10 business days after receipt of an appeal, the City Manager or his/her designee will contact the complainant to discuss the complaint or grievance and possible resolutions. Within 15 business days of this contact, the City Manager will respond in writing and, where appropriate, in a reasonable format accessible to the complainant, with a final resolution of the complaint or grievance.

Every reasonable attempt will be made by the City of Firebaugh to remedy the disability complaints or grievances in a timely manner subject to staff and budget constraints.

If any Title 24 Building Code or ADA complaint or grievance resides under the jurisdiction of another public entity, the complainant will be notified that the City of Firebaugh lacks jurisdiction and will be referred to the appropriate jurisdiction.

DRAFT

APPENDIX A: SURVEY REPORTS – FACILITIES AND PUBLIC RIGHTS OF WAY

DRAFT

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Angel
Intersection Name: 8th + 0 st

Date: 10/5/15
Ramp Location: S E corner

Compliance

- | | | | | |
|--|---|----------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>12%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>16.7%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>1.41.3%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>4%</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>No</u> | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>No</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>No</u> | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Angel
Intersection Name: 134 D St

Date: 12/12/15
Ramp Location: NE

Compliance

<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>0.2%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>6.7%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>1.2%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>0.1%</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>N/A</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>1.2%</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>0.1%</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Alvarez
Intersection Name: 13th & 6th

Date: 10/10/15
Ramp Location: NW

Compliance

<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10.9%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>6.9% - 4.3%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>3.4% - 4%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No		:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>N/A</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>N/A</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: John Date: 10/15/15
 Intersection Name: Intersection A

Ramp Location: S. 6th

Compliance

<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>11.0%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>13.9%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>4.9%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>3'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>N/A</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>No</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>No</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	<u>M. Anna</u>	Date:	<u>6/5/15</u>
Intersection Name:	<u>12th & 6th</u>	Ramp Location:	<u>S R</u>
Compliance			
:Yes	<input checked="" type="checkbox"/>	:No	<u>12.1%</u> :Actual ; Ramp slope @ 8.33% max
:Yes	<input checked="" type="checkbox"/>	:No	<u>8.7%</u> <u>10.5%</u> :Actual ; Ramp flare @ 10% max
:Yes	<input checked="" type="checkbox"/>	:No	<u>4.5%</u> <u>, 2%</u> :Actual ; Landing cross slope @ 2% max
:Yes	<input checked="" type="checkbox"/>	:No	<u>4'</u> :Actual ; Landing width @ 4 ft min
:Yes	<input checked="" type="checkbox"/>	:No	<u>4.5'</u> :Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
:Yes	<input checked="" type="checkbox"/>	:No	<u>4.5'</u> :Actual ; Detectable warning strip width @ 3 ft min
:Yes	<input checked="" type="checkbox"/>	:No	<u>4.5'</u> :Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Aunil Date: 10/5/15
Intersection Name: 12th & D Ln Ramp Location: H Tr

Compliance

<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10.3%</u>	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>7.4%</u>	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>6.8%</u>	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10</u>	:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10</u>	:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10</u>	:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>10</u>	:Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Anash
Intersection Name: 1st + 0 St

Date: 10/5/15
Ramp Location: NW

Compliance

<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>14%</u>	:Actual	; Ramp slope @ 8.33% max
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>10.4%</u>	:Actual	; Ramp flare @ 10% max
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>7.2%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>5'</u>	:Actual	; Landing width @ 4 ft min
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>No</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>11.5"</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/>	:No	<u>No</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. A. A. et al.
Intersection Name: 11th & Q St

Date: 10/5/15
Ramp Location: S 4

Compliance

- | | | | |
|--|---|--------------|---|
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>12.8%</u> | :Actual ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>10.3%</u> | :Actual ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>5.7%</u> | :Actual ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>4'</u> | :Actual ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>4.1"</u> | :Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>3.6"</u> | :Actual ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>No</u> | :Comment ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Amon
Intersection Name: 1st & D St

Date: 10/15/15
Ramp Location: S/E

Compliance

- | | | | | |
|--|---|--------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>11.4%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>13.4%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>3.5%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>6'</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>6.5"</u> | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>8.5"-</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>—</u> | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. A. G.

Intersection Name: Highway 5

Date: 12/15/15

Ramp Location: NAK

Compliance

:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	8.8%	:Actual	; Ramp slope @ 8.33% max
:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	7.5%	:Actual	; Ramp flare @ 10% max
:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	4.1%	:Actual	; Landing cross slope @ 2% max
✓ :Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	6.5%	:Actual	; Landing width @ 4 ft min
:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	All	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	All	:Actual	; Detectable warning strip width @ 3 ft min
:Yes	<input checked="" type="checkbox"/>	:No	<input type="checkbox"/>	All	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Aarvall
Intersection Name: 1st & D St

Date: 10/15/15
Ramp Location: NW

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.4%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>8.6%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>2.0%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.5%</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.5%</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.5%</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.5%</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: W. Anrich
Intersection Name: 10th + P St

Date: 10/5/15
Ramp Location: S E

Compliance

- | | | | | |
|--|------------------------------|-----------------------|---------------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5.1%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2 1/2%</u> | <u>7.5%</u> :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>9 1/2 - 10 1/2</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>11</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Ansel Date: 10/5/15
Intersection Name: 10th & P St Ramp Location: N/E

Compliance

<input checked="" type="checkbox"/>	:Yes	:No	<u>6.2%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/>	:Yes	:No	<u>6.7% - 6.4%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/>	:Yes	:No	<u>2.0% - 2.1%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/>	:Yes	:No	<u>4%</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/>	:Yes	:No	<u>3.5"</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/>	:Yes	:No	<u>3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/>	:Yes	:No	<u>3.5"</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: Jeff Amato
Intersection Name: 15th & Main

Date: 10/5/15
Ramp Location: NW

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.6%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>6.6%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>2.0%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>4'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. A. Anfuso
Intersection Name: 10th & Main

Date: 10/5/15
Ramp Location: S W

Compliance

- | | | | | |
|--|-----|-------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | :No | <u>7.5%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>7.8%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>1.8%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>4'</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Arnold
Intersection Name: 11th + P St

Date: 10/5/15
Ramp Location: S/E

Compliance

- | | | | | |
|--|------------------------------|-------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.3%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.3%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>0%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4%</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Dean Date: 10/5/15
Intersection Name: 11th & P St Ramp Location: N/E

Compliance

<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u>7.2%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u>9.4%, 7.1%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u>16%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> V :Yes	<u>No</u>	<u>4"</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u></u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u>3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<u>No</u>	<u></u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Anna
Intersection Name: 1st & Main

Date: 10/15/15
Ramp Location: 1st & Main

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.5%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.9%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.2%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>4'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Ana. S.
Intersection Name: l1st + P₂

Date: 10/5/15
Ramp Location: S. C.

Compliance

<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>6.3%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>7.4%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>14%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>4%</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u></u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>3</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> Yes	<u></u>	:No	<u>3</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREbaugh
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Auer
Intersection Name: 12th & D St

Curb Ramp		Date: <u>10/5/15</u>
		Ramp Location: <u>NW</u>
Compliance		
<input checked="" type="checkbox"/> :Yes	:No	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	:No	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	:No	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	:No	:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	:No	:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	:No	:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	:No	:Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
 2015 ADA SELF EVALUATION
 FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Amiel
 Intersection Name: Intersection 1

Date: 12/5/15
 Ramp Location: Stair

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input checked="" type="checkbox"/> :Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	M. Amerson	Date:	12/15/15
Intersection Name:	12th & Park	Ramp Location:	SE
Compliance			
<input checked="" type="checkbox"/> Yes	:No	2.4%	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> Yes	:No	7.5%	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> Yes	:No	2.0%	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> Yes	:No	5'	:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> Yes	:No		:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> Yes	:No	3'	:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> Yes	:No		:Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. M. P. Date: 10/15/15
Intersection Name: 12th & 8th Class C Ramp Ramp Location: N.E.

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>2.2%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>6.9%, 7%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>2.2%, 0%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>5%</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Amedio
Intersection Name: 1st & P St

Date: 10/15/15
Ramp Location: S. w

Compliance

- | | | | | |
|--|------------------------------|------------------|----------|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.5%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>10%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.2% - 6%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4"</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia, 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3"</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: LL. M. Hensel

Intersection Name: 13rd + P_{ct}

Date: 10/5/15

Ramp Location: SE #1

Compliance

- | | | | | |
|--|---|--------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.2%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>11.4%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.1%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6%</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>—</u> | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>—</u> | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. A. M.
Intersection Name: 13th + 4th

Date: 10/15/15
Ramp Location: SE # 2 Plaza

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>6.4%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>8.0%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>2.4%</u> , .74'	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>.4'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>.3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: W. A. J.
Intersection Name: 1st & 8th

Date: 10/5/15
Ramp Location: N E

Compliance

- | | | | | |
|--|------------------------------|------------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.4%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>9.1% 4.2%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2.0% 1.5%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.1%</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Am. J.
Intersection Name: 13th + P St

Date: 15/15/15
Ramp Location: NW

Compliance

- | | | | | | | |
|-------------------------------------|------|--------------|-----------|--------------|----------|--|
| <input checked="" type="checkbox"/> | :Yes | <u>7'</u> | :No | <u>7.5'</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> | :Yes | <u>1.41%</u> | :No | <u>1.49%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> | :Yes | <u>1.71%</u> | :No | <u>1.81%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> | :Yes | <u>4'</u> | :No | <u>4'</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> | :Yes | <u>No</u> | <u>No</u> | <u>No</u> | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> | :Yes | <u>3'</u> | :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> | :Yes | <u>No</u> | <u>No</u> | <u>No</u> | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Aueka Date: 10/15/15 Length: 500
Street Name/Side: Pine St. Limits: 102 to 114

Compliance

- :Yes :No 2%, 2%, 1%, 1.0% :Actual ; Directional slope @ 5% max
- :Yes :No 1.3%, 1.2%, 2.4%, 1.1% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 4' :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No 7' 8" :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Auvil Date: 12/5/14 Length: 500 feet
Street Name/Side: P. St. W. 1st S. Limits: 11th & 12th Street

Compliance

:Yes :No 1.7% :Actual

:Yes :No 1.67%, 49, 1.9% :Actual

:Yes :No 1.67% :Actual

:Yes :No 1.67% :Actual

:Yes :No 1.67% :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. M. S. Date: Agosto 5, 2016
Street Name/Side: P St West side Length: between 12 ft & 13 ft

Compliance

- | | | | | |
|--|-----|------------|----------|---|
| <input checked="" type="checkbox"/> :Yes | :No | <u>14%</u> | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>4%</u> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6'</u> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. B. Date: 10/15/15
Street Name/Side: P St Block S Length: 12 ft
Limits: Intersection 12 ft - 13 ft S.E.

Compliance

- | | | | | |
|--|-----|---------------------------------|--------------------------------|--|
| <input checked="" type="checkbox"/> :Yes | :No | <u>6 1/2'</u> | <u>2 1/2'</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>1 1/2' - 2 1/2' - 3 1/2'</u> | <u>1 1/2' - 2 1/2'</u> :Actual | ; Cross slope @ 2% max (incl. DWS) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>5'</u> | <u>5'</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWS) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>1 1/2"</u> | <u>1 1/2"</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. J. White Date: 10/5/15 Length: 2,000 ft ~ 500'
Street Name/Side: P. S. Gobleska Limits: beginning of block to 12th Street

Compliance

- | | | | |
|--|------------------------------|-----------------------------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4%</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4%, 2.5%, 2%, 1.5%</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.67</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: J. A. Walker Date: 10/15/15
Street Name/Side: Pine Street Length: 260 ft
Limits: 10th Street to 11th Street

Compliance

- | | | | |
|--|---|---------|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Actual | Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | Actual | Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Actual | Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Actual | Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | Comment | Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. H. Date: 10/5/15 Length: 200' of 500'
Street Name/Side: O St West Limits: 84 - 94 100' N to S

Compliance

- :Yes :No :Actual ; Directional slope @ 5% max
 :Yes :No :Actual ; Cross slope @ 2% max (incl. DWs)
 :Yes :No :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
 :Yes :No :Actual ; Vertical clear @ 6.67 ft min
 :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Arevalo Date: 1/26/16 Length: approx 500'
Street Name/Side: O St Limits: 8' - 9'

Compliance

- | | | | | |
|--|---|---------------|---------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4%</u> % | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>5.0%</u> % | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>4'</u> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>8' 2"</u> | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Angel Date: 10/5/15 Length: approx 500'
Street Name/Side: D ST West Side Limits: Intersection of D St & Main Street

Compliance

- | | | | |
|--|---|--|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>10%</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>3.69% - 1.29% - 4.19% - 1.79%</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>8.5' Min</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7'-8"</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Adel Date: 10/31/15 Length: 2,011' or 500'
Street Name/Side: O St east Limits: 9th - 12th

Compliance

- | | | | |
|--|------------------------------|-----------------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.6%</u> ; Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5'</u> ; Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7' 8"</u> ; Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Alarie Date: 10/15/15 Length: 0 ft
Street Name/Side: D St Limits: 10' - 11'

Compliance

- :Yes :No .6%, .3%, .2%; Actual ; Directional slope @ 5% max
- :Yes :No .8%, .3%, .7%, .6%; Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 5' Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No 7' 10" Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Auer Date: 10/5/15
Street Name/Side: 0 St east Length: appx 500
Limits: 12ft - 11ft

Compliance

- :Yes :No 1.2%, 70% :Actual ; Directional slope @ 5% max
- :Yes :No 1.4%, 2.1%, 1.9%, 0.8% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 5' :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No 4' :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. H. H. Date: 10/5/15
Street Name/Side: O. S. 1st St. S.E. Length: 200 ft
Limits: 110' - 120'

Compliance

- :Yes :No 29%; Actual 1.63 ft, 1.10 ft, 1.01 ft; Directional slope @ 5% max ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 1.63 ft, 1.10 ft, 1.01 ft; Actual 1.63 ft, 1.10 ft, 1.01 ft; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No 6' 10"; Actual 6' 10"; Vertical clear @ 6.67 ft min
- :Yes :No 8' 3"; Actual 8' 3"; Comment : Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Alvarado Date: 10/17/15 Length: 500'
Street Name/Side: Oak Street Limits: 12 ft

Compliance

- | | | | |
|--|------------------------------|------------------------------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>20.1% - 21.9%</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2.19%, 5%, 0% - 10%</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>8'</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6' 6"</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. Miller Date: 10/5/15 Length: 500'
Street Name/Side: Coastal Limits: 12th - 13th

Compliance

- | Compliance | :Yes | :No | :Actual | :Comment |
|---|-------------------------------------|--------------------------|-------------------------------------|---|
| Directional slope @ 5% max | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>Dir. 4.4, 10%</u> | ; Directional slope @ 5% max |
| Cross slope @ 2% max (incl. DWs) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>99.2.7%, 419, 4.1%</u> | ; Cross slope @ 2% max (incl. DWs) |
| Sidewalk width @ 4 ft min (inc. DWs) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>1/2 block 4' - 1/2 block 5'</u> | ; Sidewalk width @ 4 ft min (inc. DWs) |
| Vertical clear @ 6.67 ft min | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | ; Vertical clear @ 6.67 ft min |
| Walk surface is continuous, without steps or bumps that exceed 1/2" | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Allen Date: 12/16/15
Street Name/Side: D st east side Length: 2 ft - 12 ft
Limits: 12' to 13'

Compliance

- :Yes :No :Actual 30% 1.5% 6%; Directional slope @ 5% max
- :Yes :No :Actual 10% 1% 2.4% 2.7%; Cross slope @ 2% max (incl. DWs)
- :Yes :No :Actual 11.1% 4% 11.1% 11.1%; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No :Actual 7' 1"; Vertical clear @ 6.67 ft min
- :Yes :No :Comment Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: John J. J. Date: 10/5/2015
Street Name/Side: 10th St South side Length: 2 ft
No Sidewalk Limits: DSL - GSD

Compliance

:Yes _____ :No _____ :Actual _____ ; Directional slope @ 5% max

:Yes _____ :No _____ :Actual _____ ; Cross slope @ 2% max (incl. DWs)

:Yes _____ :No _____ :Actual _____ ; Sidewalk width @ 4 ft min (inc. DWs)

:Yes _____ :No _____ :Actual _____ ; Vertical clear @ 6.67 ft min

:Yes _____ :No _____ :Comment _____ ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: 10n St Date: 10/15/15
Street Name/Side: 50' of sidewalk @ PSL Length: 2,300 ft
Limits: P1 to P2

Compliance

- :Yes :No 1.40%, 1.60% :Actual ; Directional slope @ 5% max
- :Yes :No 1.40%, 1.60% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 5' :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No _____ :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Amato Date: 10/5/15
Street Name/Side: 10th St N Length: 2 ft
SW Limits: 5th St E 11th St E

Compliance

- | | | | | | |
|------|-------------------------------------|----|--------------------------|----------|---|
| :Yes | <input checked="" type="checkbox"/> | No | <input type="checkbox"/> | :Actual | :Cross slope @ 5% max |
| :Yes | <input checked="" type="checkbox"/> | No | <input type="checkbox"/> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| :Yes | <input checked="" type="checkbox"/> | No | <input type="checkbox"/> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| :Yes | <input checked="" type="checkbox"/> | No | <input type="checkbox"/> | :Actual | ; Vertical clear @ 6.67 ft min |
| :Yes | <input checked="" type="checkbox"/> | No | <input type="checkbox"/> | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: John Nastasi Date: 10/5/15 Length: 400
Street Name/Side: N. 5th - O. 5th Limits: N. 5th - O. 5th

Compliance

- | | | | |
|--|---|-------------------------------|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 4% ; Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | 1.1%, 5%, 2.4%, 2.4% ; Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 7.4% ; Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | Actual | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. Baile Date: 10/5/14 Length: 400'
Street Name/Side: 10th Street Limits: N. 10th St. to Dcl

Compliance

- :Yes :No 2%, 8.56 ft :Actual ; Directional slope @ 5% max
- :Yes :No 2.3%, 1.17 ft :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 4 ft :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No None :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No No :Actual ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: John S. Schellin Date: 10/5/15
Street Name/Side: 10th St Length: approx 400'
Limits: D - P

Compliance

- | | | | |
|--|---|---|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1%</u> , <u>.2%</u> , <u>.2%</u> , <u>.4%</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>1.4%</u> , <u>1.6%</u> , <u>1.4%</u> , <u>1.9%</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5'</u> <u>5'</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>N/A</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | Comment _____ | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Arevalo Street Name/Side: 1st St S. - South Side Date: 10/15/15 Length: 200 ft
Limits: Dawn - Pm

Compliance

- :Yes :No 42" :Actual ; Directional slope @ 5% max
- :Yes :No 2.6% - 0% :Actual ; Cross slope @ 2% max (incl. DWS)
- :Yes :No No White Stripes on App Sidewalk :Actual ; Sidewalk width @ 4 ft min (inc. DWS)
- :Yes :No 8.5" :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Amos Date: 10/21/16 Length: 4
Street Name/Side: W. 1st St. Limits: Firebaugh Rd.

Compliance

- | | | | |
|--|------------------------------|---------------------------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 0% ; Actual | Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 1.5%, 1.6%, 1.4%, 2.0% ; Actual | Cross slope @ 2% max {incl. DWs} |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Min. 4" ; Actual | Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 9' 8" ; Actual | Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. H. H. Date: 10/25/15 Length: 400'
Street Name/Side: 1st St N.E. Limits: West - Dist.

Compliance

- :Yes :No 2.4% 1.2% - 4.1% :Actual ; Directional slope @ 5% max
- :Yes :No 5.6% 1.2% - 4.1% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 5' :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No 7' :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No 7' :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: MM Date: 1/15 Length: 450
Street Name/Side: 11th South Limits: Not - Deck

Compliance

- :Yes _____ :No .1%, .2%, .1.0%, .2% :Actual ; Directional slope @ 5% max
- :Yes _____ :No .3%, .4%, .3.6%, .1.4% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes _____ :No .11, .10 :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes _____ :No .11, .10 :Actual ; Vertical clear @ 6.67 ft min
- :Yes _____ :No .11, .10 :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. Mirek Date: 10/10/15 Length: 4 ft
Street Name/Side: 12th St - Northbound Limits: 0 to 20 ft

Compliance

- :Yes :No 9.1% / 1.89% / 15.0% :Actual ; Directional slope @ 5% max
- :Yes :No 7.5% / 1.1% / 5.9% / 3.1% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 10.0% / 4' :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No None :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Aguilera Date: 10/17/15 Length: 400 ft
Street Name/Side: 12th St N Side: North Limits: Near - D St

Compliance

- | | | |
|--------|-----|--|
| :Yes | :No | 1.1% - 2.4%, 2% :Actual ; Directional slope @ 5% max |
| :Yes | :No | 6.7%, 3.7% , 2.5%, 1.5% :Actual ; Cross slope @ 2% max (incl. DWs) |
| ✓ :Yes | :No | Min 4' :Actual ; Sidewalk width @ 4 ft min (inc. DWs) |
| ✓ :Yes | :No | 6' 11" :Actual ; Vertical clear @ 6.67 ft min |
| ✓ :Yes | :No | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Hause Date: 10/5/15 Length: On paper 530
Street Name/Side: 1st St Sides Limits: Neg - Dsl

Compliance

- :Yes _____ :No 89.10.1.29.79 Actual ; Directional slope @ 5% max
:Yes _____ :No 3.47, 1.71, 5.22, 4.71 Actual ; Cross slope @ 2% max (incl. DWs)
:Yes _____ :No _____ Actual ; Sidewalk width @ 4 ft min (inc. DWs)
:Yes _____ :No None Actual ; Vertical clear @ 6.67 ft min
:Yes _____ :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Mancuso Date: 12/15/2015
Street Name/Side: 12th St. South Length: 400 ft.
Limits: City Park Rd.

Compliance

- :Yes :No :Actual :Comment
✓ 19°, 20°, 41°, 49° ; Directional slope @ 5% max
- :Yes :No :Actual :Comment
✓ 2.47%, 4.9%, 1.01%, 3.37% ; Cross slope @ 2% max (incl. DWs)
- :Yes :No :Actual :Comment
✓ 7.5' ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No :Actual :Comment
✓ 7' 2" ; Vertical clear @ 6.67 ft min
- :Yes :No :Actual :Comment
✓ All ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Aguirre Date: 10/5/13 Length: 0 ft
Street Name/Side: 1st St Sides Limits: None - 0 ft

Compliance

- | | | | | | | |
|------|-------------------------------------|----|-------------------|--------------------|-------------|--|
| :Yes | <input checked="" type="checkbox"/> | No | <u>20% - 5.0%</u> | <u>3.6% - 9.1%</u> | :Actual | ; Directional slope @ 5% max |
| :Yes | <input checked="" type="checkbox"/> | No | <u>2.4%</u> | <u>4.9%</u> | <u>1.0%</u> | <u>3.1%</u> :Actual ; Cross slope @ 2% max (incl. DWS) |
| :Yes | <input checked="" type="checkbox"/> | No | <u>4'</u> | | | :Actual ; Sidewalk width @ 4 ft min (inc. DWS) |
| :Yes | <input checked="" type="checkbox"/> | No | <u>4'</u> | | | :Actual ; Vertical clear @ 6.67 ft min |
| :Yes | <input checked="" type="checkbox"/> | No | | | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Anne L.
Street Name/Side: 1st St S. Wall St.
Date: 10/5/15
Length: 200 ft
Limits: 0 st - Pct

Compliance

- | | | | | | |
|---|-----|----------------|-------------------------|----------|---|
| <input type="checkbox"/> Yes | :No | <u>5%</u> | <u>4% , 4.5% , 6%</u> | :Actual | ; Directional slope @ 5% max |
| <input type="checkbox"/> Yes | :No | <u>2.7%</u> | <u>2.1% , 5% , 4.8%</u> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> Yes | :No | <u>Min. 4'</u> | | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> Yes | :No | <u>None</u> | | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> Yes | :No | <u>✓</u> | | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Mays Date: 10/5/15 Length: 2,100'
Street Name/Side: 1st St Sidewalk: South side Limits: From 2nd St to 8th St

Compliance

- | | | | | |
|--|---|---|--------------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 2.7% :Actual | 1.6% :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | 2.8% :Actual | 3.4% :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | 5' :Actual | 5' :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | None :Actual | None :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" | | |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Morris Date: 10/15/15 Length: 0 ft - 0 in
Street Name/Side: 13th St Side: R Limits: 13th St - D

No Sidewalk

Compliance

- | | | | |
|------|-----|----------|---|
| :Yes | :No | :Actual | ; Directional slope @ 5% max |
| :Yes | :No | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| :Yes | :No | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| :Yes | :No | :Actual | ; Vertical clear @ 6.67 ft min |
| :Yes | :No | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)
Surveyor: M. Wier Date: 10/5/15 Length: On block 1/2
Street Name/Side: D Street North Side Limits: Between 100 & 105

Compliance

- :Yes :No 1.3% , 7% , 8% :Actual ; Directional slope @ 5% max
- :Yes :No 2.7% , 1% , 2.6% , 8.6% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No 4' min. :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No None :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No _____ :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. A. M. A. Date: 10/5/15 Length: approx 400
Street Name/Side: Dixie St North Side Limits: D st - D St

Compliance

- :Yes :No 1.5% :Actual ; Directional slope @ 5% max
- :Yes :No 6.4%, 49, 41.5%, 2.2% :Actual ; Cross slope @ 2% max (incl. DWs)
- :Yes :No No Sidewalk :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
- :Yes :No No :Actual ; Vertical clear @ 6.67 ft min
- :Yes :No No :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. A. M. Date: 10/21/15
Intersection Name: Q ST & 11th St Ramp Location: N. w. C. 2112

Compliance

- | | | | | |
|--|-----|-------------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | :No | <u>6.2%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>8.87. 7.9%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>8%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>7.1%</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | <u>7.1%</u> | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6</u> | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: John C. G. Date: 10/21/15
Intersection Name: Bentley St Ramp Location: Near Garage

Compliance

- | | | | | |
|--|-----|-------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | :No | <u>7.7%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> Yes | :No | <u>7.0%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> Yes | :No | <u>1.2</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> Yes | :No | | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> Yes | :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> Yes | :No | <u>6</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> Yes | :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Angel

Date: 10/21/15
Intersection Name: Ramp at 9th
Ramp Location: SW corner

Compliance

- | | | | | |
|--|------------------------------|--------------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.2'</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5.2' - 7.4'</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.3'</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6'</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Ansel
Intersection Name: 0 S 1st St 10° C+

Date: 10/21/15
Ramp Location: NW corner

Compliance

- | | | | | |
|--|------------------------------|-------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>7.3%</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2.9%</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.6%</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6"</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Hensel
Intersection Name: Q St & 10th St

Date: 10/21/15
Ramp Location: Sidewalk Curb ramp

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>6.4%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>4.3%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.2%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. L. M. Date: 2/12/15
Street Name/Side: Allegan Avenue Length: 100 ft
Limits: City of Firebaugh to eastward

Compliance

- | | | | | |
|---|--|-----------------------------|----------|---|
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | <u>15.4 ft. O.</u> | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | <u>No Sidewalk (O.D.U.)</u> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | <u>No Sidewalk (A.D.U.)</u> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | <u>No Obscure</u> | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Alvarado Date: 10/22/15
Street Name/Side: North Main Street Length: 600 ft
Limits: Intersection of Main Street & North Main Street

Compliance

- | | | | | |
|---|-----|--------------------------------|----------|---|
| <input checked="" type="checkbox"/> Yes | :No | <u>6.1.2, 4.1</u> | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> Yes | :No | <u>4.0% to 4.1</u> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> Yes | :No | <u>6</u> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> Yes | :No | <u>1.0 feet</u> | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> Yes | :No | <u>1.0 between S.D. Panels</u> | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: _____ Date: _____ Length: _____
Street Name/Side: _____ Limits: _____

Compliance

- | | | | | |
|--|-----|---------------------|----------|---|
| <input checked="" type="checkbox"/> :Yes | :No | 5, 1, 10, 5 | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | 1, 3, 8, 1, 5, 2, 7 | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | 1, 3, 8, 1, 5, 2, 7 | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | No Ramps | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | _____ | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: BLA, Muni.
Intersection Name: Trans. St. & 2nd St.

Date: 10/2
Ramp Location: S E corner

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>5.2</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.5</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>2%</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: John J. Dickey

Intersection Name: Clifford Avenue & Avenue Loring

Compliance		Date: <u>10/2</u>		Ramp Location: <u>SLC Curb</u>	
<input checked="" type="checkbox"/> Yes	:No	<u>8.2</u>	:Actual	; Ramp slope @ 8.33% max	
<input checked="" type="checkbox"/> Yes	:No	<u>9.7</u>	:Actual	; Ramp flare @ 10% max	
<input checked="" type="checkbox"/> Yes	:No	<u>.2</u>	:Actual	; Landing cross slope @ 2% max	
<input checked="" type="checkbox"/> Yes	:No		:Actual	; Landing width @ 4 ft min	
<input checked="" type="checkbox"/> Yes	:No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)	
<input checked="" type="checkbox"/> Yes	:No		:Actual	; Detectable warning strip width @ 3 ft min	
<input checked="" type="checkbox"/> Yes	:No		:Comment	; Gutter lip flushed with ramp	

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. M. M. Date: 12/1/15 Length: 100 ft
Street Name/Side: Thomas Road E side Limits: between City Hall and Town Hall

Compliance

- | | | | |
|--|---|--|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5.1.3.4</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.0.7.1.7</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>Distance to Senior Center No Wrap around Wall</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1.0.7.1.1.1</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>All steps 1.0 exceed 1'</u> :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: Parkers Park Date: 10/2/15 Length: 17 ft
Street Name/Side: limits: Park entrance from the South end

Compliance

- | | | | | |
|--|-----|-----------------|----------|---|
| <input checked="" type="checkbox"/> :Yes | :No | 2.5% | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | 17% | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | 5' | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | No Obstructions | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |



CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Angel Date: 10/20/15

Facility Name: Senior Center Floor: _____

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.

ID

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

:Item Name Item Name :Yes / :No / :Actual /

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Anash
Intersection Name: 15th & Q St.

Date: 10/21/15
Ramp Location: Side Canal

Compliance

- | | | | | |
|--|------------------------------|----------------|----------|--|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.7</u> | :Actual | ; Ramp slope @ 8.33% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.7 8.3</u> | :Actual | ; Ramp flare @ 10% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>5</u> | :Actual | ; Landing cross slope @ 2% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>6.7</u> | :Actual | ; Landing width @ 4 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3'</u> | :Actual | ; Detectable warning strip width @ 3 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | | :Comment | ; Gutter lip flushed with ramp |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: J. J. Firebaugh
Street Name/Side: Locust Street
Date: 10/21/15
Length: Approx 500'
Limits: 15th & 16th

Compliance

- | | | | |
|--|------------------------------|------------------------------------|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>3, 10, 0, 3</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>1, 2, 1, 1, 1, 7, 8</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2, 1, 0, 2</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2</u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | <u>2</u> :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Aanek
Intersection Name: 16th & R St

Date: 12/21/15
Ramp Location: N. 16th Corner

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.1%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>5.1%</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.17</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.17</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.17</u>	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>3</u>	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	Date: <u>10/21/15</u>		
Intersection Name:	Ramp Location: <u>Ramp 1 on S. 4th Street</u>		
Compliance			
<input checked="" type="checkbox"/> :Yes	:No	<u>6.0</u>	<u>6.7</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>1.5</u>	<u>2.0</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>1.5</u>	<u>2.0</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>5'</u>	<u>5'</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>5'</u>	<u>5'</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>3'</u>	<u>3'</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>3'</u>	<u>3'</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>3'</u>	<u>3'</u>
<input checked="" type="checkbox"/> :Yes	:No	<u>3'</u>	<u>3'</u>
:Actual ; Ramp slope @ 8.33% max			
:Actual ; Ramp flare @ 10% max			
:Actual ; Landing cross slope @ 2% max			
:Actual ; Landing width @ 4 ft min			
:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)			
:Actual ; Detectable warning strip width @ 3 ft min			
:Comment ; Gutter lip flushed with ramp			

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Ainslie Date: 12/2/15 Length: 100 ft
Street Name/Side: Q St Limits: 125' E. Main St. to 125' E. Main St.

Compliance

- :Yes :No :Actual ; Directional slope @ 5% max
 :Yes :No :Actual ; Cross slope @ 2% max (incl. DWs)
 :Yes :No :Actual ; Sidewalk width @ 4 ft min (inc. DWs)
 :Yes :No :Actual ; Vertical clear @ 6.67 ft min
 :Yes :No :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Amick Date: 10/21/16
Intersection Name: West Main Street Ramp Location: SE Corner

Compliance

<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>6.5%</u>	:Actual	<u>6.5%</u>	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>8.1%</u>	:Actual	<u>8.1%</u>	; Ramp flare @ 10% max
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>1.91%</u>	:Actual	<u>1.91%</u>	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>4.1'</u>	:Actual	<u>4.1'</u>	; Landing width @ 4 ft min
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>Comment</u>	:Comment	<u>Comment</u>	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>3 ft min</u>	:Actual	<u>3 ft min</u>	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/>	:Yes	<input type="checkbox"/> :No	<u>Comment</u>	:Comment	<u>Comment</u>	; Gutter lip flushed with ramp

**CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM**

Municipal Facility

Surveyor: _____ Date: 10/21/15 Facility Name: _____ Floor: _____ Final Poll, Primary, Secondary, Preliminary

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.

ID	Compliance	:Item No.	<u>Hand Polk</u>	:Item Name	<u>To Public R.R.</u>	:Yes	<u>✓</u>	:No	<u>5</u>	:Actual	<u>No</u>	:Actual	<u>Cross Slope, Decking Slip Good</u>
		:Item No.		:Item Name		:Yes		:No		:Actual			
		:Item No.	<u>Hand Polk</u>	:Item Name	<u>To Public R.R.</u>	:Yes		:No		:Actual			
		:Item No.	<u>Ramp D D</u>	:Item Name	<u>DS Ties not full</u>	:Yes		:No		:Actual			
		:Item No.		:Item Name		:Yes		:No		:Actual			
		:Item No.		:Item Name		:Yes		:No		:Actual			
		:Item No.		:Item Name		:Yes		:No		:Actual			
		:Item No.		:Item Name		:Yes		:No		:Actual			

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Ansel Date: 10/21/13
Facility Name: Community Center Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID

Compliance	:Actual	:Actual	:Actual	:Actual	:Actual	:Actual	:Actual	:Actual	:Actual
:Item No. <u>Public Stalls</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public W.I.</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Restrooms</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap Restrooms</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap Stalls</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap W.I.</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap Handicap Restrooms</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap Handicap Stalls</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						
:Item No. <u>Public Handicap Handicap W.I.</u> :Item Name <u>✓</u> :Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>						

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: Debra Dugay Date: 12/21/15
Facility Name: Debra Dugay Floor:

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance	
:Item No. <u>1</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>1/8</u> :Actual ; <u>Floor sink holes</u>
:Item No. <u>2</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>1</u> :Actual ; <u>Restroom floor holes</u>
:Item No. <u>3</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>1</u> :Actual ; <u>Restroom floor holes</u>
:Item No. <u>4</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>4</u> :Actual ; <u>Washroom</u>
:Item No. <u>5</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>9.7</u> :Actual ; <u>Restroom floor holes</u>
:Item No. <u>6</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>1</u> :Actual ; <u>Restroom floor holes</u>
:Item No. <u>7</u> :Item Name <u>Restroom</u>	<input checked="" type="checkbox"/> :Yes	<u>4</u> :Actual ; <u>Restroom floor holes</u>

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Anderson Date: 10/21/14
Facility Name: City Hall Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance	
:Item No. <u>Washroom</u>	:Item Name <u>/</u> :Yes <u>/</u> :No <u>12.5%</u> :Actual <u>/</u>	; <u>Accessible Slope Max 5%</u>
:Item No. <u>Dishwashing</u>	:Item Name <u>/</u> :Yes <u>/</u> :No <u>/</u> :Actual <u>/</u>	; <u>Hand Sink 12' wide</u>
:Item No. <u>Wash sink</u>	:Item Name <u>/</u> :Yes <u>/</u> :No <u>/</u> :Actual <u>/</u>	; <u>Two 12" sinks 24" apart</u>
:Item No. <u>Wash sink</u>	:Item Name <u>/</u> :Yes <u>/</u> :No <u>4'</u> :Actual <u>/</u>	; <u>Min. width 48"</u>
:Item No. <u>Wktrms.</u>	:Item Name <u>/</u> :Yes <u>/</u> :No <u>7</u> :Actual <u>/</u>	; <u>gross floor area 1000 sq ft</u>
:Item No. _____	:Item Name _____ :Yes _____ :No _____ :Actual _____	_____
:Item No. _____	:Item Name _____ :Yes _____ :No _____ :Actual _____	_____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Anish Date: 10/26/15
Facility Name: Pal Building Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID

Compliance

- :Item No. Parking Lot :Item Name Parking lot, Towed Park :Yes :No Actual ; Parking lot No parking restrictions
- :Item No. Hand Dall :Item Name Hand dallas :Yes :No Actual ; Hand dallas 20% cross slope
- :Item No. Sidewalk :Item Name Sidewalk :Yes :No Actual ; No sidewalk, side of building
- :Item No. Sidewalk :Item Name Sidewalk :Yes :No Actual ; Sidewalk in front of building
- :Item No. Berries :Item Name Berries :Yes :No Actual ; Small Scale berries 17"-19"
- :Item No. Books :Item Name Books :Yes :No Actual ; Large books, books & backrest 2" Max
- :Item No. Dishwash :Item Name Dishwash :Yes :No Actual ; Min. 44"

**CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM**

Curb Ramp

Surveyor: _____ Intersection Name: _____

Date: 1/21/15
Ramp Location: Alji's Conv.

Date: 1/21/15
Ramp Location: Alji's Conv.

Compliance

Actual	;	Ramp slope @ 8.33% max
Actual	;	Ramp flare @ 10% max
Actual	;	Landing cross slope @ 2%
Actual	;	Landing width @ 4 ft min
Actual	;	Comment ; Detectable warning surface domes, 0.9" dia., 0.2" h, 2 contrasting color)
Actual	;	Detectable warning strip w 3 ft min

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Ann L. Date: 10/10/15 Length: Approx 500'
Street Name/Side: West Main S. L. Limits: 13^{ft} - 14^{ft}

Compliance

- | | | | |
|--|---|--------------------------------|---|
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>8', 7', 26.43'</u> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>14', 12.8', 15'</u> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u>5'</u> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u></u> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | <u></u> :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Marshall
Intersection Name: 13th & D

Date: 10/21/15
Ramp Location: SW corner

Compliance

<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	14.6	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	10.4	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	2.2	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No		:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	All dimensions	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	All dimensions	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Ansel
Intersection Name: 13th & 5th

Date: 10/21/15
Ramp Location: 512 Curb

Compliance

<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Actual	; Ramp slope @ 8.33% max
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Actual	; Ramp flare @ 10% max
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<input type="checkbox"/> :No	:Actual	; Landing width @ 4 ft min
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Actual	; Detectable warning strip width @ 3 ft min
<input type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<input type="checkbox"/> :No	:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Amiel Date: 10/21/15 Length: Approx 5000
Street Name/Side: W 2nd Street Limits: 124 to 144

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>W 2nd Street</u> :Actual	; Directional slope @ 5% max
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>2nd Street</u> :Actual	; Cross slope @ 2% max (incl. DWs)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>W 2nd Street</u> :Actual	; Sidewalk width @ 4 ft min (inc. DWs)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>W 2nd Street</u> :Actual	; Vertical clear @ 6.67 ft min
<input checked="" type="checkbox"/> :Yes	<input checked="" type="checkbox"/> :No	<u>W 2nd Street</u> :Comment	; Walk surface is continuous, without steps or bumps that exceed 1/2"

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. Moore
Intersection Name: Oak & 14th

Date: 10/2/15
Ramp Location: NE corner

Compliance

<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>7.5%</u>	:Actual	; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>9.2 + 4.6</u>	:Actual	; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>1.4</u>	:Actual	; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>4'</u>	:Actual	; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No	<u>6'</u>	:Actual	; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	<input type="checkbox"/> :No		:Comment	; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. B. M. Date: 12/1/15 Length: _____
Street Name/Side: 1st Street Limits: 1st Street - 1st Street

Compliance

- | | | | | |
|--|-----|---------------------------|----------|---|
| <input checked="" type="checkbox"/> :Yes | :No | <u>4.0%</u> | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | <u>1.7, 1.4, 1.3, 1.6</u> | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6</u> | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6.67</u> | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | <u>6.67</u> | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: _____ Date: _____ Length: _____
Street Name/Side: Main Street Limits: Street End Kiosk

Compliance

- | | | | |
|--|---|----------|---|
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | <input checked="" type="checkbox"/> :No | :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | <input type="checkbox"/> :No | :Comment | ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	H. H.		Date:	10/21/15	
Intersection Name:	Mission & 1st		Ramp Location:	Side of Travel -	
Compliance					
<input checked="" type="checkbox"/> :Yes	:No	7.5%	:Actual	; Ramp slope @ 8.33% max	
<input checked="" type="checkbox"/> :Yes	:No	5%	:Actual	; Ramp flare @ 10% max	
<input checked="" type="checkbox"/> :Yes	:No	2.6% to 1.4%	:Actual	; Landing cross slope @ 2% max	
<input checked="" type="checkbox"/> :Yes	:No		:Actual	; Landing width @ 4 ft min	
<input checked="" type="checkbox"/> :Yes	:No	N/A	:Comment	; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)	
<input checked="" type="checkbox"/> :Yes	:No	N/A	:Actual	; Detectable warning strip width @ 3 ft min	
<input checked="" type="checkbox"/> :Yes	:No		:Comment	; Gutter lip flushed with ramp	

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	Date: <u>10/26/15</u>		
Intersection Name:	Ramp Location: <u>N E corner</u>		
Compliance			
<input checked="" type="checkbox"/> Yes	:No	<u>7.3%</u>	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> Yes	:No	<u>9.4%</u>	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> Yes	:No	<u>17%</u>	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> Yes	:No		:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> Yes	:No	<u>No Domes</u>	Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<u>No Gutter</u>	:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<u>Gutter</u>	Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Sidewalks (per city block)

Surveyor: M. Ainsworth Date: 1/21/15
Street Name/Side: Elm Street Length: 0
Limits: Dw 1. end of Elm Street to Dw 420

Compliance

- | | | | |
|--|-----|---|--|
| <input checked="" type="checkbox"/> :Yes | :No | <input checked="" type="checkbox"/> :Actual | ; Directional slope @ 5% max |
| <input checked="" type="checkbox"/> :Yes | :No | <input checked="" type="checkbox"/> :Actual | ; Cross slope @ 2% max (incl. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | <input checked="" type="checkbox"/> :Actual | ; Sidewalk width @ 4 ft min (inc. DWs) |
| <input checked="" type="checkbox"/> :Yes | :No | <input checked="" type="checkbox"/> :Actual | ; Vertical clear @ 6.67 ft min |
| <input checked="" type="checkbox"/> :Yes | :No | | :Comment ; Walk surface is continuous, without steps or bumps that exceed 1/2" |

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor:	Date: <u>March 2016</u>		
Intersection Name:	Ramp Location: <u>M. S. Black House</u>		
Compliance			
<input checked="" type="checkbox"/> :Yes	:No	<u>7.14%</u>	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> :Yes	:No	<u>11.5%</u>	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> :Yes	:No	<u>11.5%</u>	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> :Yes	:No		:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> :Yes	:No		:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> :Yes	:No		:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> :Yes	:No		:Comment ; Gutter lip flushed with ramp

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Curb Ramp

Surveyor: M. And
Intersection Name: Spurc

Compliance			
<input checked="" type="checkbox"/> Yes	:No	<u>7.3</u>	:Actual ; Ramp slope @ 8.33% max
<input checked="" type="checkbox"/> Yes	:No	<u>Glass C Ramps N. 6.6</u>	:Actual ; Ramp flare @ 10% max
<input checked="" type="checkbox"/> Yes	:No	<u>1.9%</u>	:Actual ; Landing cross slope @ 2% max
<input checked="" type="checkbox"/> Yes	:No	<u>11'</u>	:Actual ; Landing width @ 4 ft min
<input checked="" type="checkbox"/> Yes	:No	<u>2.35</u>	:Comment ; Detectable warning surface (truncated domes, 0.9" dia., 0.2" h, 2.35" OC, contrasting color)
<input checked="" type="checkbox"/> Yes	:No	<u></u>	:Actual ; Detectable warning strip width @ 3 ft min
<input checked="" type="checkbox"/> Yes	:No	<u></u>	:Comment ; Gutter lip flushed with ramp

Date: <u>10/21/15</u>
Ramp Location: <u>W. 2nd blck in front of Park</u>
<u>South Side</u>

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: John H. H. Date: 10/20/15
Facility Name: Public Works Floor: 1

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID

Compliance

:Item No.	<u>Link</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>33</u>	:Actual	<u>/</u>
:Item No.	<u>Public Works</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>60</u>	:Actual	<u>/</u>
:Item No.	<u>100</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>17</u>	:Actual	<u>/</u>
:Item No.	<u>100</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>11</u>	:Actual	<u>/</u>
:Item No.	<u>100</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>39</u>	:Actual	<u>/</u>
:Item No.	<u>100</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>45</u>	:Actual	<u>/</u>
:Item No.	<u>100</u>	:Item Name	<u>/</u>	:Yes	<u>/</u>	:No	<u>59</u>	:Actual	<u>/</u>

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. A. Aar Date: 10/21/15
Facility Name: Baker Park Room: 2, 2

Men R.R.

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID

Compliance

- | ID | :Item No. | :Item Name | :Yes | :No | :Actual | : |
|----|------------|------------------|-------------------------------------|--------------------------|-----------|---|
| | <u>101</u> | <u>Arc</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>60</u> | |
| | <u>101</u> | <u>Item Name</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>7</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>33</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>58</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>11</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>40</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>11</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>33</u> | |
| | <u>101</u> | <u>Hard Rail</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>33</u> | |

DRA

V

V

V

V

V

**CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM**

Municipal Facility

Surveyor: M. Amin **Date:** 10/2/15
Facility Name: Dakla Park **Floor:** 1st floor

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.

Compliance ID

ID :Item No. Sink :Item Name Sink :Yes ✓ :No 29 :Actual ; _____
Compliance _____
accessible paths, etc.

:Item No. 12345 :Item Name Arc :Yes _____ :No 60 :Actual ; _____

:Item No. _____ :Item Name _____ :Yes _____ :No _____ :Actual ; _____

:Item No. 1.15 :Item Name i/ :Yes _____ :No _____ :Actual ; _____

Item No. _____ Item Name _____ Description _____

:Item No. _____ :Item Name _____ :Yes _____ :No _____ :Actual _____ ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Mun. Date: 10/21/15
Facility Name: Bakel's Park Floor: _____
Women's Rest

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance		
:Item No.	:Item Name	:Yes	:No
	<u>Sink</u>	<input checked="" type="checkbox"/>	<u>29"</u> :Actual ; _____
	<u>Toilet Area</u>	<input checked="" type="checkbox"/>	<u>60"</u> :Actual ; _____
	<u>Toilet</u>	<input checked="" type="checkbox"/>	<u>60"</u> :Actual ; _____
	<u>10' Drop</u>	<input checked="" type="checkbox"/>	<u>9'</u> :Actual ; _____
	<u>Handicap</u>	<input checked="" type="checkbox"/>	<u>9'</u> :Actual ; _____
	<u>No Handicap</u>	<input checked="" type="checkbox"/>	<u>9'</u> :Actual ; _____
	<u>10' Drop</u>	<input checked="" type="checkbox"/>	<u>10'</u> :Actual ; _____
	<u>Handicap</u>	<input checked="" type="checkbox"/>	<u>10'</u> :Actual ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: VFW Hall Date: 10/11/18
Facility Name: Women's P.L.C. Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance	
:Item No. <u>145</u>	:Item Name <u>✓</u> :Yes	:No <u>35</u> :Actual ; _____
:Item No. <u>146</u>	:Item Name <u>✓</u> :Yes	:No <u>22</u> :Actual ; _____
:Item No. <u>Handicap</u>	:Item Name <u>✓</u> :Yes	:No <u>55</u> :Actual ; _____
:Item No. <u>Handicap</u>	:Item Name <u>✓</u> :Yes	:No <u>60</u> :Actual ; _____
:Item No. <u>147</u>	:Item Name <u>✓</u> :Yes	:No <u>17</u> :Actual ; _____
:Item No. <u>148</u>	:Item Name <u>✓</u> :Yes	:No <u>9</u> :Actual ; _____
:Item No. <u>149</u>	:Item Name <u>✓</u> :Yes	:No <u>54</u> :Actual ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: VFW Veterans Hall Date: 10/11/15

Facility Name: Merc R.R. Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance	
:Item No. <u>Sinks</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>35"</u> :Actual <u>24"</u> <i>check top is 24"</i>	
:Item No. <u>M. Jdg</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>SD</u> :Actual ;	
:Item No. <u>Rest and Rest</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>48"</u> :Actual ;	
:Item No. <u>ADA Sign</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>60"</u> :Actual ;	
:Item No. <u>ADA</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>17"</u> :Actual ;	
:Item No. <u>ADA</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>12"</u> :Actual ;	
:Item No. <u>ADA</u>	:Item Name <u>/</u> :Yes <input checked="" type="checkbox"/> :No <u>54"</u> :Actual ;	

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/1/15
Facility Name: Veterans Hall Vf4 Floor: _____

Main Room

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID

Compliance	
:Item No. <u>Counters</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>44 1/2</u> :Actual <u>44 1/2</u>
:Item No. <u>Toilet #2</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>44 1/2</u> :Actual <u>44 1/2</u>
:Item No. <u>Toilet #4</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>36</u> :Actual <u>36</u>
:Item No. <u>Handicap</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>1,18</u> :Actual <u>1,18</u>
:Item No. <u>Handicap</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>1,18</u> :Actual <u>1,18</u>
:Item No. <u>Handicap</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>1,18</u> :Actual <u>1,18</u>
:Item No. <u>Handicap</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>1,18</u> :Actual <u>1,18</u>
:Item No. <u>Handicap</u>	:Item Name <u>C</u> :Yes <u>✓</u> :No <u>1,18</u> :Actual <u>1,18</u>

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/16

Facility Name: Public Dining Room
(Compliant Room)

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

Compliance

ID	:Item No.	:Item Name	:Yes	:No	:Actual	
	<u>A-07</u>	<u>Access</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Access</u>	
	<u>A-08</u>	<u>Hand Wash</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Hand Wash</u>	
	<u>A-09</u>	<u>Tables</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Tables</u>	
	<u>A-10</u>	<u>Tables</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Tables</u>	
	<u>Sink</u>	<u>Sink</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Sink</u>	
	<u>10.00 ft</u>	<u>10.00 ft</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>10.00 ft</u>	

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/10/15
Facility Name: Pal building Floor: 1
Public Safety

Restroom

ID

Compliance	
:Item No. <u>A002</u>	:Item Name <u>Dish Dishes</u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>28"</u>
:Item No. <u>No Hand Mats</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>/</u> :Actual <u></u>
:Item No. <u>Sink</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>71"</u>
:Item No. <u>XQ Disp</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>30"</u>
:Item No. <u>Hand Towel</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>44"</u>
:Item No. <u>Hand Soap</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>47"</u>
:Item No. <u>Wash</u>	:Item Name <u></u> :Yes <u>/</u> :No <u>✓</u> :Actual <u>56"</u>

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: Mark Harkins Date: 10/1/15
Facility Name: Firebaugh Library Floor: 1

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance	
:Item No. <u>Arc</u>	:Item Name <u>✓</u> :Yes	:No <u>75"</u> :Actual ; _____
:Item No. <u>11</u>	:Item Name <u>✓</u> :Yes	:No <u>17"</u> :Actual ; _____
:Item No. <u>Hand Rail</u>	:Item Name <u>✓</u> :Yes	:No <u>54"</u> :Actual ; _____
:Item No. <u>Salt</u>	:Item Name <u>✓</u> :Yes	:No <u>37"</u> :Actual ; _____
:Item No. <u>M. Harkins</u>	:Item Name <u>✓</u> :Yes	:No <u>40"</u> :Actual ; _____
:Item No. <u>Mark Harkins</u>	:Item Name <u>✓</u> :Yes	:No <u>37"</u> :Actual ; _____
:Item No. <u>Mark Harkins</u>	:Item Name <u>✓</u> :Yes	:No <u>21"</u> :Actual ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/11/15
Facility Name: Sequoia Park Floor: _____

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance		
:Item No. <u>Counters /</u>	:Item Name <u>✓</u>	:Yes	:No <u>38"</u> :Actual ; _____
:Item No. <u>Handrails /</u>	:Item Name <u>✓</u>	:Yes	:No <u>35"</u> :Actual ; _____
:Item No. <u>Public Counters</u>	:Item Name <u>✓</u>	:Yes	:No <u>35"</u> :Actual ; _____
:Item No. <u>Water fountain</u>	:Item Name <u>✓</u>	:Yes	:No <u>26"</u> :Actual ; _____
:Item No. _____	:Item Name _____	:Yes	:No _____ :Actual ; _____
:Item No. _____	:Item Name _____	:Yes	:No _____ :Actual ; _____
:Item No. _____	:Item Name _____	:Yes	:No _____ :Actual ; _____
:Item No. _____	:Item Name _____	:Yes	:No _____ :Actual ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/11/15
Facility Name: Spinal Care Floor: _____

ID	Compliance		
	:Item No.	:Item Name	:Yes :No
			60": Actual ; <u>60"</u>
			48": Actual ; <u>48"</u>
			48": Actual ; <u>48"</u>
			32": Actual ; <u>32"</u>
			75": Actual ; <u>75"</u>
			72": Actual ; <u>72"</u>
			48": Actual ; <u>48"</u>
			48": Actual ; <u>48"</u>

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: Connie Park Date: 10/1/15
Facility Name: Concierge Park Floor: _____

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.

ID	Item Name	Compliance	Actual
:Item No. <u>5-1</u>	:Item Name <u>Tables - Area</u>	:Yes	:No <u>36"</u> :Actual ; _____
:Item No. <u>5-2</u>	:Item Name <u>Hand Sink</u>	:Yes	:No <u>35"</u> :Actual ; _____
:Item No. <u>5-3</u>	:Item Name <u>Toilet</u>	:Yes	:No <u>36"</u> :Actual ; _____
:Item No. <u>5-4</u>	:Item Name <u>Hand Soap Dispenser</u>	:Yes	:No <u>53"</u> :Actual ; _____
:Item No. <u>5-5</u>	:Item Name <u>Tables - Kitchen</u>	:Yes	:No <u>53"</u> :Actual ; _____
:Item No. <u>5-6</u>	:Item Name <u>Tables - Kitchen</u>	:Yes	:No <u>36"</u> :Actual ; _____
:Item No. <u>5-7</u>	:Item Name <u>Tables - Kitchen</u>	:Yes	:No <u>36"</u> :Actual ; _____

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: _____ Date: 10/11/15
Facility Name: Firebaugh Park Floor: _____

Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.
*Distance from center of curb to wall
is 6' 6 1/2" on Due Street*

ID	Item Name	Compliance	Actual
:Item No.	<u>Sink</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>32'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>Soil Drap</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>41'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>W/</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>41'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>Tank Drap</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>41'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>Tables</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>31'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>Tables</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>17'</u> :Actual ; <u>6' 6 1/2"</u>
:Item No.	<u>Tables</u>	:Item Name <input checked="" type="checkbox"/> Yes	:No <u>17'</u> :Actual ; <u>6' 6 1/2"</u>

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility

Surveyor: M. Anch Date: 10/1/15
Facility Name: Community Center Floor: _____

ID	Item Name	Compliance		Actual	Comments
		:Yes	:No		
1	<u>Mess Room</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>34</u>	Threshold for items such as counters, restrooms, drinking fountains, telephones, entrance doors, accessible paths, etc.
2	<u>Handicap Restroom</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>36</u>	
3	<u>Handicap Accessible Counter</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>57</u>	
4	<u>Handicap Accessible Telephone</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>57</u>	
5	<u>Handicap Accessible Entrance</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>17</u>	
6	<u>Handicap Accessible Path</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>32</u>	

CITY OF FIREBAUGH
2015 ADA SELF EVALUATION
FIELD SURVEY FORM

Municipal Facility


Surveyor: M. Anick Date: 10/1/15
Facility Name: City Hall Floor: 1

Threshold for items such as counters, restrooms,
drinking fountains, telephones, entrance doors,
accessible paths, etc.

ID	Compliance		
	:Item No.	:Item Name	:Yes :No :Actual
	:Item No. <u>Sink</u>	:Item Name <u>Sink</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>No Sink</u> :Actual
	:Item No. <u>Toilet</u>	:Item Name <u>Toilet</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>Toilet</u> :Actual
	:Item No. <u>Wash</u>	:Item Name <u>Wash</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>48"</u> :Actual
	:Item No. <u>Hand</u>	:Item Name <u>Hand</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>15"</u> :Actual
	:Item No. <u>Door</u>	:Item Name <u>Door</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>18"</u> :Actual
	:Item No. <u>Table</u>	:Item Name <u>Table</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>24"</u> :Actual
	:Item No. <u>Chair</u>	:Item Name <u>Chair</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>18"</u> :Actual
	:Item No. <u>Door</u>	:Item Name <u>Door</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>36"</u> :Actual
	:Item No. <u>Table</u>	:Item Name <u>Table</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>30"</u> :Actual
	:Item No. <u>Chair</u>	:Item Name <u>Chair</u>	<input checked="" type="checkbox"/> :Yes <input type="checkbox"/> :No <u>18"</u> :Actual

APPENDIX B: PROW PRIORITY AREAS LOCATION MAP

DRAFT



CITY OF FIREBAUGH
2016 ADA SELF EVALUATION PLAN
PROW PRIORITY AREAS

EXHIBIT 1
DRAWN BY
A. THOMSON
DATE 4/6/2016
PROJECT NUMBER
710.10

GOUVEIA ENGINEERING, INC.
CONSULTING ENGINEERS

456 Sixth Street • Gustine, California 95322
Telephone (209) 854-3300 • Fax (209) 854-3600



APPENDIX C: PUBLIC NOTICE AND POSTING

DRAFT



Public Notice and Posting City of Firebaugh

Notice to the Public of the Self-Evaluation

The City of Firebaugh is seeking the public's input for its ongoing self-evaluation of the Americans with Disabilities Act (ADA). Areas to be considered include facility and program accessibility, accommodations for individuals with disabilities, and administrative policies and procedures.

Individuals who would like to provide input are invited to complete a survey. Surveys are available for organizations that represent individuals with disabilities, community members, employees, and other interested individuals who wish to participate in the evaluation.

Your comments and opinions are important to us and will provide valuable information regarding how the City of Firebaugh can better accommodate individuals with disabilities. Surveys can be mailed to you or are available at:

City of Firebaugh
City Hall
1133 "P" Street
Firebaugh, CA 93622

If you have questions or comments, or to request a survey be mailed to you, please contact Rita Lozano, Deputy City Clerk at (559) 659-2043, or email deputyclerk@ci.firebaugh.ca.us. Information regarding the Americans with Disabilities Act can be obtained from the ADA Coordinator, Ben Gallegos, Public Works Director or online at <http://www.ada.gov/>.

The City of Firebaugh complies with the Americans with Disabilities Act of 1990, Public Law 101-336, which prohibits discrimination on the basis of disability.



Registro y Aviso Público

Ciudad de Firebaugh

Aviso al Público de la Autoevaluación

La ciudad de Firebaugh invita al público a que aporten sugerencias al plan de auto evaluación con el Americans with Disabilities Act (ADA). Áreas en consideración incluyen instalación y accesibilidad de programa, alojamientos para personas con discapacidad y las políticas administrativas y procedimientos.

Se invitan a personas que quieran aportar para completar una encuesta. Las encuestas están disponibles para las organizaciones que representan a personas con discapacidades, miembros de la Comunidad, empleados y otras personas interesadas que deseen participar en la evaluación.

Sus comentarios y opiniones son importantes para nosotros y proporcionarán información valiosa acerca de cómo la ciudad de Firebaugh puede mejor acomodar personas con discapacidad. Las encuestas pueden enviarse a usted o están disponibles en:

Ayuntamiento de la Ciudad de Firebaugh
1133 Calle "P"
Firebaugh, CA 93622

Si tiene alguna pregunta o comentario, o para solicitar una encuesta, póngase en contacto con Rita Lozano, Clerk de la Ciudad en (559) 659-2043, o por correo electrónico deputyclerk@ci.firebaugh.ca.us. Información sobre la ley de estadounidenses con discapacidades puede ser obtenida del Coordinador de ADA, Ben Gallegos, Director de Obras Públicas o en línea en <http://www.ada.gov/>.

La ciudad de Firebaugh cumple con los Americans with Disabilities Act de 1990, ley pública 101-336, que prohíbe la discriminación sobre la base de la discapacidad.

**APPENDIX D: SURVEY FOR ORGANIZATIONS AND INDIVIDUALS WITH
DISABILITIES**

DRAFT



**Americans with Disabilities Act
Survey for Organizations and Individuals with Disabilities
City of Firebaugh**

The City of Firebaugh is continuously updating its self-evaluation with the Americans with Disabilities Act. In order to enhance access to programs and services for individuals with disabilities, the City of Firebaugh is asking for your input.

NAME OF ORGANIZATION OR INDIVIDUAL:

Address: _____ Contact Person: _____

Position: _____

Phone: _____ Date: _____

Name of person Completing this form: _____

The following questions have been developed to determine how organizations and advocacy agencies perceive the City of Firebaugh's ability to provide services and accommodations for individuals with disabilities and to ask for input regarding how programs, services and activities can be more accessible for individuals with disabilities.

1. What direct communications have you had with the City of Firebaugh to facilitate services and accommodations for individuals with disabilities?

2. Are there any specific complaints or problems regarding access for individuals with disabilities to any of the programs, services or activities provided by the City of Firebaugh?

3. What information or other resources can you supply to help educate or inform the City of Firebaugh about your organization and your services for individuals with disabilities?

4. What general guidance, advice or assistance could your organization provide to the City of Firebaugh to protect against potential discrimination of individuals with disabilities in its programs, services and activities?

5. What do you feel is the highest priority for the City of Firebaugh to improve accessibility for individuals with disabilities?

Please add any additional comments on the back of this survey or attach any additional documents. *Thank you for your input.*

Please return this survey to:

City of Firebaugh
ADA Coordinator
1133 "P" Street
Firebaugh, CA 93622

Surveys can also be emailed to deputyclerk@ci.firebaugh.ca.us or faxed to (559) 659-3412.

If you have questions or comments to address directly with the City of Firebaugh, please contact Ben Gallegos, Public Works Director and ADA Coordinator at (559) 659-2043, e-mail at publicworks@ci.firebaugh.ca.us or fax to (559) 659-3412.



Americans with Disabilities Act
Encuesta para las Organizaciones y Personas con Discapacidad
Ciudad de Firebaugh

La ciudad de Firebaugh esta constantemente actualizando la autoevaluación con el Americans with Disabilities Act (ADA). A fin de mejorar el acceso a programas y servicios para personas con discapacidad, la ciudad de Firebaugh está pidiendo sus sugerencias.

NOMBRE DE LA ORGANIZACIÓN O INDIVIDUO:

Dirección: _____

Persona de Contacto: _____

Posición: _____

Teléfono: _____

Fecha: _____

Nombre de la persona que completa este formulario: _____

Se han desarrollado las siguientes preguntas para determinar cómo las organizaciones y grupos de derechos perciben la capacidad de la ciudad de Firebaugh para prestar servicios y alojamiento para personas con discapacidad y para pedir sugerencias acerca de cómo pueden ser más accesibles para las personas con discapacidad los programas, servicios y actividades.

¿Qué comunicación directa ha tenido con la ciudad de Firebaugh para facilitar servicios y alojamiento para las personas con discapacidad?

¿Existen quejas específicas o problemas de acceso para personas con discapacidades en cualquiera de los programas, servicios o actividades de la ciudad de Firebaugh?

¿Qué información o otros recursos puede proporcionar para ayudar a educar o informar a la ciudad de Firebaugh sobre su organización y sus servicios para personas con discapacidad?

¿Qué orientación general, asesoramiento o asistencia podría proporcionar su organización a la ciudad de Firebaugh para protegerse de la posible discriminación de las personas con discapacidad en sus programas, servicios y actividades?

¿Qué crees que es la máxima prioridad para la ciudad de Firebaugh para mejorar la accesibilidad para personas con discapacidad?

Por favor añadir comentarios adicionales en la parte posterior de esta encuesta o adjuntar los documentos adicionales. **Gracias por tu aportación.**

Por favor devuelva esta encuesta al:

Ciudad de Firebaugh
ADA Coordinador
1133 Calle "P"
Firebaugh, CA 93622

Encuestas también pueden ser enviadas por correo electrónico a deputyclerk@ci.firebaugh.ca.us o por fax al (559) 659-3412.

Si tienes preguntas o comentarios directos a la ciudad de Firebaugh, póngase en contacto con Ben Gallegos, Director de Obras Públicas y Coordinador de ADA al (559) 659-2043, por correo electrónico a citymanager@ci.firebaugh.ca.us o por fax al (559) 659-3412.

APPENDIX E: NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT

DRAFT



NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT

In accordance with the requirements of title II of the Americans with Disabilities Act of 1990 ("ADA"), the City of Firebaugh will not discriminate against qualified individuals with disabilities on the basis of disability in its services, programs, or activities.

Employment: The City of Firebaugh does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under title I of the ADA.

Effective Communication: The City of Firebaugh will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in the City of Firebaugh's programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

Modifications to Policies and Procedures: The City of Firebaugh will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services, and activities. For example, individuals with service animals are welcomed in the City of Firebaugh offices, even where pets are generally prohibited.

Anyone who requires an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a program, service, or activity of the City of Firebaugh, should contact the office of Ben Gallegos, ADA Coordinator, as soon as possible but no later than 48 hours before the scheduled event. The ADA Coordinator's office is located at City Hall, 1133 "P" Street, Firebaugh, CA 93622 and may be reached at (559) 659-2043.

The ADA does not require the City of Firebaugh to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

Complaints that a program, service, or activity of the City of Firebaugh is not accessible to persons with disabilities should be directed to Ben Gallegos, ADA Coordinator. The ADA Coordinator's office is located at City Hall, 1133 "P" Street, Firebaugh, CA 93622 and may be reached at (559) 659-2043.

The City of Firebaugh will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use wheelchairs.



AVISO Conforme al Americans With Disabilities Act

Conforme con los requisitos del Título II de la Ley de Americanos con Discapacidades de 1990 ("ADA"), la Ciudad de Firebaugh no discrimina a personas calificadas con discapacidad de acuerdo a la ley en el ofrecimiento de sus servicios, programas o actividades.

Empleo: La ciudad de Firebaugh no discrimina basado en la condición de discapacidad en el proceso de contratación de empleo y cumple con todas las regulaciones promulgadas por la Comisión de Igualdad de Oportunidades en el Empleo EE.UU., bajo el título I de la ADA.

Comunicación Efectiva: La ciudad de Firebaugh por lo general, si se solicita, proporciona ayudas y servicios apropiados que conducen a una comunicación efectiva para las personas con discapacidad calificadas para que puedan participar por igual en los programas, servicios y actividades ofrecidos por la ciudad de Firebaugh, incluyendo intérpretes de lenguaje basado en signos, documentos en Braille y otras formas de información y comunicación accesible a las personas con impedimentos del habla, el oído o la vista.

Las Modificaciones a las Pólizas y Procedimientos: La ciudad de Firebaugh realizará todas las modificaciones razonables a las pólizas y programas para asegurar que las personas con discapacidad tengan igualdad de oportunidades para disponer de todos sus programas, servicios y actividades. Por ejemplo, los individuos que dependen en animales de servicio son recibidos en el Ayuntamiento de oficinas Firebaugh, aun cuando en general, se prohíben las mascotas.

Cualquier persona que requiere una ayuda o servicio auxiliar para la comunicación efectiva, o una modificación de las pólizas o procedimientos para participar en un programa, servicio o actividad de la Ciudad de Firebaugh, debe contactar a la oficina de Ben Gallegos, Coordinador de ADA, tan pronto como sea posible pero no más tarde de 48 horas antes del evento programado. La oficina del Coordinador de ADA se encuentra en el Ayuntamiento, 1133 Calle "P", Firebaugh, CA 93622 y puede ser llamado al número (559) 659-2043.

La ADA no requiere que la Ciudad de Firebaugh tome cualquier acción que altere fundamentalmente la naturaleza de sus programas o servicios, o imponer una carga financiera o administrativa indebida.

Las quejas sobre un programa, servicio o actividad de la Ciudad de Firebaugh que no es accesible para personas con discapacidad deben ser dirigidas a Ben Gallegos, Coordinador del ADA. La oficina del Coordinador de ADA se encuentra en el Ayuntamiento, 1133 Calle "P", Firebaugh, CA 93622 y puede ser llamado al número (559) 659-2043.

La Ciudad de Firebaugh no impondrá ningún recargo a un individuo en particular con una discapacidad o cualquier grupo de personas con discapacidad para cubrir el costo de proporcionar ayudas auxiliares / servicios o modificaciones razonables de la póliza, como la recuperación de los artículos en lugares que están abiertos al público, pero no son accesibles a las personas que utilizan sillas de ruedas.

APPENDIX F: CITY OF FIREBAUGH ADA COMPLAINT FORM

DRAFT



City of Firebaugh ADA Complaint / Grievance Form

Complainant: _____

Person Preparing Complaint (if different from Complainant): _____

Relationship to Complainant (if different from Complainant): _____

Street Address & Apt. No.: _____

City: _____ State: _____ Zip: _____

Phone: (_____) _____ E-mail: _____

Please provide a complete description of the specific complaint or grievance:

Please specify any location(s) related to the complaint or grievance (if applicable):

Have efforts been made to resolve this complaint through the Citizen Request Process?

Yes No

If yes, what were the results? _____

Please state what you think should be done to resolve the complaint or grievance:

Please attach additional pages as needed.

Signature: _____ **Date:** _____

Return to:

Ben Gallegos
ADA Coordinator and Public Works Director
1133 "P" Street
Firebaugh, CA 93622
publicworks@ci.firebaugh.ca.us

Upon request, reasonable accommodation will be provided in completing this form, or copies of the form will be provided in alternative formats. Contact the Program Access Coordinator at the address listed above, via telephone (559) 659-2043



City of Firebaugh Formulario ADA de Quejas/Reclamos

Quejante/Demandante: _____

Persona Preparando Queja (si es diferente del demandante): _____

Relación con el demandante (si es diferente del demandante): _____

Domicilio y numero de apartamento: _____

Ciudad: _____ Estado: _____ Código postal: _____

Teléfono: (_____) _____ Correo Electronico: _____

Por favor, proporcione una descripción completa de la queja o reclamación específica:

Por favor especifique cualquier ubicación (s) en relación con la queja o reclamo (si procede):

Se han hecho esfuerzos para resolver esta queja a través del proceso de solicitud de ciudadano?

Si No

En caso afirmativo, ¿cuáles fueron los resultados?

Por favor, indique lo que usted piensa que debería hacerse para resolver la queja o reclamo:

Por favor incluya páginas adicionales para describir la queja si es necesario.

Firma: _____ **Fecha:** _____

Entregue formulario a:

Ben Gallegos
Coordinador del ADA y Director de Obras Publicas
1133 "P" Street
Firebaugh, CA 93622
publicworks@ci.firebaugh.ca.us

A petición, los ajustes razonables serán proporcionados para completar este formulario, o se proporcionará copias de la forma en formatos alternativos. Póngase en contacto con el Coordinador del ADA a la dirección indicada más arriba, o a través del teléfono (559) 659-2043.

RESOLUTION NO. 16-24

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF FIREBAUGH AUTHORIZING THE CITY MANAGER TO EXECUTE AMENDMENT NO 3. TO MID-VALLEY DISPOSAL AGREEMENT FOR WASTE DISPOSAL AND FOR COLLECTION OF RECYCLABLE MATERIALS

This amendment is made and entered into this _____ day of _____ 2016 (the "Effective Date") by and between the City of Firebaugh, a municipal Corporation, hereinafter designated "City", and Mid Valley Disposal, Inc, a California corporation hereinafter designated "Collector"

WITNESSED:

WHEREAS, City, in carrying on its municipal functions, furnishes garbage and rubbish removal services, which said services its inhabitants are required to use exclusively, and

WHEREAS, it is the desire of the City to amend its march 20, 2001, "Agreement for Waste Disposal and for Collection of Recyclable Materials" as amended by the Assumption Agreement and Amendment No.'s 1 and 2 (the "Agreement") with Collector, and

WHEREAS, the rates in the Agreement as of the date of this amendment were established by City Council Resolution No. 11-03, and

WHEREAS, the City has requested an amendment to the Agreement with Collector,

NOW, THEREFORE, it is understood and agreed by and between the hereto and the parties agree to this amendment as follows:

- A. Paragraph 2 of Section 16 of the Agreement is hereby amended to read as follows:

"Collector agrees that in exchange for the City granting the exclusive franchise, City may require Collector to pay a franchise fee equal to 15.0% of revenues billed by City for residential collection service. City may withhold franchise fee from monthly remittances paid to Collector."

- B. In all other respects, the Agreement for Waste Disposal and for Collection of Recyclable Materials, dated March 20, 2001, as amended, shall remain in full force and effect.

MID-VALLEY DISPOSAL

By: _____
Joseph Kalpakoff
Chief Executive Officer

CITY OF FIREBAUGH

By: _____
Ben Gallegos, Acting City Manager
City of Firebaugh

The foregoing resolution was approved and adopted by the City Council of the City of Firebaugh, on the 20th day of June 2016, by the following votes:

AYES: Board Members
NOES: Board Members
ABSENT: Board Members
ABSTAIN: Board Members

APPROVED:

Freddy Valdez
Mayor

ATTEST:

Rita Lozano
Deputy City Clerk

EXHIBIT A

City of Firebaugh

Refuse Rates

Garbage Service	Current Rates	New Rates
Residential Customers		
3-96 Carts	\$19.27	\$23.77*
Senior	\$16.21	\$20.72*
Commercial Customers		
Commercial 96 Gal	\$19.27	\$20.35
1X Week Service		
1.5 Yard Bin	\$60.57	\$63.98
3 Yard Bin	\$69.58	\$73.49
2X Week Service		
1.5 Yard Bin	\$95.18	\$100.53
3 Yard Bin	\$111.36	\$117.62
3X Week Service		
1.5 Yard Bin	\$136.36	\$144.03
3 Yard Bin	\$146.69	\$154.94
4X Week Service		
1.5 Yard Bin	\$166.85	\$176.24
3 Yard Bin	\$177.84	\$187.84
5X Week Service		
1.5 Yard Bin	\$205.88	\$217.46
3 Yard Bin	\$217.47	\$229.70

* Residential rates now include a 15.0% franchise fee per Amendment No. 3 to the contract.

RESOLUTION NO. 16-25**RESOLUTION OF THE CITY OF FIREBAUGH ORDERING AN ELECTION ON
MEASURE " ", REQUESTING COUNTY ELECTIONS TO CONDUCT THE
ELECTION, AND REQUESTING CONSOLIDATION OF THE ELECTION**

WHEREAS, pursuant to Elections Code Section 10002, the governing body of any city or district may by resolution request the Board of Supervisors of the county to permit the county elections official to render specified services to the city or district relating to the conduct of an election; and

WHEREAS, the resolution of the governing body of the city or district shall specify the services requested; and

WHEREAS, pursuant to Elections Code Section 10002, the city or district shall reimburse the county in full for the services performed upon presentation of a bill to the city or district; and

WHEREAS, pursuant to Elections Code Section 10400, whenever two or more elections, including bond elections, of any legislative or congressional district, public district, city, county, or other political subdivision are called to be held on the same day, in the same territory, or in territory that is in part the same, they may be consolidated upon the order of the governing body or bodies or officer or officers calling the elections; and

WHEREAS, pursuant to Elections Code Section 10400, such election for cities and special districts may be either completely or partially consolidated; and

WHEREAS, pursuant to Elections Code Section 10403, whenever an election called by a district, city or other political subdivision for the submission of any question, proposition, or office to be filled is to be consolidated with a statewide election, and the question, proposition, or office to be filled is to appear upon the same ballot as that provided for that statewide election, the district, city or other political subdivision shall, at least 88 days prior to the date of the election, file with the board of supervisors, and a copy with the elections official, a resolution of its governing board requesting the consolidation, and setting forth the exact form of any question, proposition, or office to be voted upon at the election, as it is to appear on the ballot. Upon such request, the Board of Supervisors may order the consolidation; and

WHEREAS, the resolution requesting the consolidation shall be adopted and filed at the same time as the adoption of the ordinance, resolution, or order calling the election; and

WHEREAS, various district, county, state and other political subdivision elections may be or have been called to be held on November 3, 2016; and

WHEREAS, the City desires to adopt Ordinance No. 16-0____ to impose a 5% utility user's tax on wireless telecommunication services, subject to a simple majority (50% plus 1) voter approval, as required by Cal. Const., art. XIIC, § 2(b); and

WHEREAS, by Resolution 13-04, the City Council declared by unanimous vote that a fiscal emergency exists in the City of Firebaugh pursuant to Article XIII C § 2(b) of the California Constitution which requires an election to approve a tax to be consolidated with a regularly scheduled general election for members of the governing body of the local government, except in cases of emergency declared by a unanimous vote of the governing body; and

WHEREAS, the City Attorney shall prepare an impartial analysis of the Measure.

NOW, THEREFORE, BE IT RESOLVED AND ORDERED that the governing body of the City of Firebaugh hereby orders a traditional General election be called and consolidated with any and all elections also called to be held on November 3, 2016 insofar as said elections are to be held in the same territory or in territory that is in part the same as the territory of the County of Fresno, requests the Board of Supervisors of the County of Fresno to order such consolidation under Elections Code Section 10401 and 10403.

BE IT FURTHER RESOLVED AND ORDERED that said governing body hereby requests the Board of Supervisors to permit the Fresno County Elections Department to provide any and all services necessary for conducting the election and agrees to pay for said services, and

BE IT RESOLVED AND ORDERED that the Fresno County Elections Department shall conduct the election for the following MEASURE, designated as Measure “____”, to be voted on at the November 3, 2016 general election:

Measure to be voted on:

Measure “____” Ballot Question:

“Shall an ordinance be adopted to amend the City's Utility Users Tax in order to impose a 5% utility user's tax on new telecommunication technologies such as wireless and voice over internet services?

Yes [] No []”

BE IT FURTHER RESOLVED AND ORDERED that the Fresno County Elections Department is requested to print the attached measure text exactly as filed or indicated on the filed document in the Voter's Information Pamphlet section of the Sample Ballot for the November 3, 2016 election. Cost of printing and distribution of the measure text will be paid for by the city.

The foregoing resolution was approved and adopted at a regular meeting of the City Council of the City of Firebaugh held on the 20th day of June, 2016, by the following vote:

AYES: Council Members
NOES: Council Members
ABSTAIN: Council Members
ABSENT: Council Members

APPROVED:

Freddy Valdez
Mayor

ATTEST:

Rita Lozano
Deputy City Clerk

**NOTICE OF DATE FIXED FOR SUBMITTING ARGUMENTS
ON THE CITY OF FIREBAUGH UTILITY TAX MEASURE**

NOTICE IS HEREBY GIVEN to all qualified electors in the City of Firebaugh of Fresno County California that on Tuesday, November 3, 2016, there will be submitted to the voters the following measure:

**Measure B
Adding Utility Users Tax for Cell Phones**

“Shall an ordinance be adopted to amend the City’s Utility Users Tax in order to impose a 5% utility user’s tax on new telecommunication technologies such as wireless and voice over internet services?

Yes _____ No _____

Arguments for or against the measure may be submitted to the Fresno County Clerk/Elections, 2221 Kern St., Fresno, CA 93721, no later than Day, Month Date, 2016. No argument shall exceed 300 words in length. The legislative body, or any member or members of the legislative body authorized by that body, or any individual voter who is eligible to vote on the measure, or bona fide association of citizens, or any combination of voters and associations may submit arguments. No more than five signatures shall appear with any argument submitted. If an argument is signed by more than five persons, the names of only the first five persons signing, determined by the order in which their signatures appear, shall be printed with the argument.

Only one argument for and one argument against each measure will be selected for printing and distribution to the voters. Preference and priority in selection will be given in the order named: (1) The legislative body, or member or members of the legislative body authorized by that body; (2) The individual voter, or bona fide association of citizens, or combination of voters and associations, who are the bona fide sponsors or proponents of the measure; (3) Bona fide associations of citizens; (4) Individual voters who are eligible to vote on the measure. Any argument submitted shall not be changed after Day, Month Date, 2016.

ALL ARGUMENTS submitted shall be verified in substantially the following form:

VERIFICATION

The undersigned author(s) of the _____ (primary/rebuttal) argument _____ (in favor of/against) ballot measure (name or number) at the _____ (title of election) election for the _____ (jurisdiction) to be held on _____, (date) hereby state that such argument is true and correct to the best of _____ (his/her/their) knowledge and belief.

Signed _____ Date _____

Dated: _____

BRANDI L. ORTH
County Clerk/Registrar of Voters

By _____
(name)
Elections Program Technician

Quienes deseen obtener la versión española de este aviso legal pueden solicitar una copia de la misma Llamando al Departamento de Elecciones, (559) 600-8683.

1185 N Street Firebaugh, CA




1185 N Street is located along Firebaugh's busiest commercial corridor and has excellent development potential. Located 43 miles west of Fresno and 17 miles east of Interstate 5, Firebaugh has a strong demand for almost every type of commercial development. Lucrative Enterprise Zone incentives, first-rate city services, and a growing population all make Firebaugh an excellent place to locate a business.

**ASKING PRICE
\$45,000**

APN: 008-074-10
Lot Size: 10,018 SqFt
Zoning: C-3 Commercial
Max Height: 35 Feet / 2 Stories

2015 Population:	5,400	8,204	8,604
2015 Households:	1,435	2,116	2,252
2015 Median Age:	28.1	27.8	27.8
2015 Ave. HH Income:	\$40,348	\$40,386	\$40,727



RSG, INC.

309 West 4th Street, Santa Ana, CA 92701
Ph: 714-541-4585, Fax: 714-541-1175
www.webrsg.com
CalBRE Broker License #01930929

Jeff Khau

Ph: 714-316-2136
sales@webrsg.com
CalBRE Broker License #01891467